



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Janet T. Mills  
GOVERNOR

Bruce A. Van Note  
COMMISSIONER

May 13, 2020  
Subject: Large Culvert Replacement  
State WIN: 021772.00  
Location: **Columbia**  
**Amendment No. 1**

Dear Sir/Ms.:

The following questions have been received:

**Question:** Can 96" Option 3 Polymer coated CSP in 12 ga 5" x 1" corrugations be used?

**Response:** The Department will not allow the use of 96" Option 3 Polymer Coated CSP.

**Question:** Or if smooth interior required perhaps 96" Steel Reinforced HDPE DuroMaxx like was used under Rt 1 in Warren ME?

**Response:** The Department will not allow the use of 96" Steel Reinforced HDPE DuroMaxx Pipe.

Consider these changes and information prior to submitting your bid on **May 20, 2020**.

Sincerely,

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer